

Product Certification Schedule

Schedule No: 218/001/001
Licensee: DATWYLER CABLING SOLUTIONS AG, GOTTHARDSTRASSE 31, CH-6460
ALTDORF, SWITZERLAND
Factory: DATWYLER, FACTORY 218, EUROPE
Specification: BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant,
screened, fixed installations cables having low emission of smoke and
corrosive gases when affected by fire. Part 1 : Multicore cables
Type of Cable: Table 2 Dimensions of 2-core, 3-core and 4-core cables
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.0sqmm nominal cross-sectional area of conductor. 2-core.
1.5sqmm to 4.0sqmm nominal cross-sectional area of conductors inclusive.
2-core to 4-core inclusive.
STANDARD 60.
Additionally tested to BS 6387 Categories C, W & Z
Sheath - LTS3. Insulation - EI2.
Origin Thread: Not applicable
Origin Mark: 218 and DATWYLER DFS ST

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/12/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 15/01/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004