

Product Certification Schedule

Schedule No: 153/001/044

Licensee: DATWYLER CABLING SOLUTIONS AG, GOTTHARDSTRASSE 31, CH-6460
ALTDORF, SWITZERLAND

Factory: DATWYLER CABLING SOLUTIONS AG, GOTTHARDSTRASSE 31, CH-6460
ALTDORF, SWITZERLAND

Specification: I.S. 3218:2013 Fire Detection and Fire Alarm Systems for Buildings - System
Design, Installation, Commissioning, Servicing and Maintenance

Type of Cable: Standard fire resistant cable requirements of I.S. 3218:2013 6.14.2.2 utilising
BS 7629-1:2015, tested to I.S. EN 50200:2006 (PH120 classification) and
Annex E of I.S. EN 50200:2006

Range of Approval: 1.0sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive.
Two-core to four-core inclusive. Sheath - LTS3. Insulation - E15.

Origin Thread: Not applicable

Origin Mark: DATWYLER (;) DATWYLER DFS EN (;) DATWYLER DFS ST



PERMISSIBLE MARKS

BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 02/12/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 08/08/2018

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



0004